

4250201 INLETS, MANHOLES, AND JUNCTION BOXES
COMMENTS FROM INTERNAL/INDUSTRY REVIEW



Dan Hurtado
(850) 414-5203
Dan.Hurtado@dot.state.fl.us

Comments: (11/10/20, Industry)

Why do we mention performance turf in 425-8?

Response: Payment information was removed from the 425 Standard Plans Indexes.

In order to ensure that the Turf is paid for separately, the decision was made to reference it in the Specification.

Tim Holley, P.E.
Senior Drainage Design Engineer
Roadway Design Office
Florida Department of Transportation
Phone: (850) 414-4117

