

5200602 SPECIFICATION  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW



Dan Hurtado  
dan.hurtado@dot.state.fl.us

Comments: (11-19-20, Industry)

Delete the sentence, "For joints between curb and concrete pavement, construct expansion with preformed joint filler and joint seal." This is simply repeating language from the Design Standard. If you're just addressing measurement and payment, there's no need to change the workmanship language.

Response:

