

EXPECTED IMPLEMENTATION JULY 2021

522 CONCRETE SIDEWALK AND DRIVEWAYS (REV 11-13-20) (FA 1-12-21) (7-21)

ARTICLE 522-2 is expanded by the following:

522-2 Materials.

Meet the requirements specified in 520-2 and the embankment utilization requirements of Standard Plans Index 120-001.

ARTICLE 522-4 is deleted and the following substituted:

522-4 Foundation.

Shape and compact the foundation materials with suitable equipment to a firm, even surface, true to grade and cross-slope. Compact cut-and-fill areas within 1 foot beyond each side of the sidewalk or driveway, when right-of-way conditions allow. Meet the testing frequency and maximum lift thickness requirements of Section 120. Record density test results in the Earthwork Records System (ERS) section of the Department's database for the foundation material below the bottom of concrete for a minimum depth of 2 feet for fill areas, and 1 foot for cut areas, to a density not less than 95% of the maximum density as determined by FM 1-T099. Compact the material in the remaining fill areas to match the adjacent area density.

D

R

A

F

T