

EXPECTED IMPLEMENTATION JULY 2021

635 PULL, SPLICE, AND JUNCTION BOXES (REV 2-1-21) (FA 2-3-21) (7-21)

SUBARTICLE 635-2.2.1 is deleted and the following substituted:

635-2.2 Pull and Splice Boxes:

635-2.2.1 General: Use only boxes that meet the requirements of Section 996 and are listed on the Department's Approved Product List (APL). Ensure box bodies and covers are free of flaws such as cracks, sharp, broken, or uneven edges, and voids.

Ensure in-ground boxes have an open bottom design.

SUBARTICLE 635-2.2.2 is deleted and the following substituted:

635-2.2.2 Marking: Mark boxes in accordance with 996-5..

SUBARTICLE 635-2.2.3 is deleted and the following substituted:

635-2.2.3 Dimensions: Unless otherwise shown in the Plans, provide pull and splice boxes with dimensions in accordance with 996-5.

SUBARTICLE 635-2.2.4 is deleted:

SUBARTICLE 635-2.2.5 is deleted:

SUBARTICLE 635-3.1 is deleted and the following substituted:

635-3 Installation.

635-3.1 General: Do not install power and communication cables in the same box unless otherwise shown in the Plans.

When signal or 120 volt (or greater) power is present, ground all metal covers in accordance with Section 620.

Ensure metal junction boxes are grounded and bonded in accordance with the NEC Section 314.4.