

1040400 PREVENTION, CONTROL, AND ABATEMENT OF EROSION AND WATER POLLUTION
COMMENT AND RESPONSE FROM INDUSTRY REVIEW

.....
Unknown

Comments: (11-5-21)

Recommend removal of the phrase "the Engineer will base acceptance on visual inspection". Reason(s): It has been my understanding that we typically do not state what the Engineer will do in specifications language.

Response:

Change made. While we do not normally identify what the Engineer will do, the specification does need to identify acceptance criteria.
