

3460200 STRUCTURAL PORTLAND CEMENT CONCRETE
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

.....
Dan Hurtado
(850) 414-5203
Dan.Hurtado@dot.state.fl.us

Comments: (11-5-21, Internal)

The following sentence in 346-2.4.2 is not needed. LWFA for internal curing is already addressed in 902-7

“The requirements for LWFA suitable for internal curing are specified in ASTM C1761.”

Response:

Jeff O’Leary
(904) 868-9875
jeffo@alblock.com

Comments: (12-8-21, Industry)

Sections 2.2 & 2.3 allow a Type IT cement. However, the only cement requirement listed in section 2.1 is Section 921. Section 921 does not list IT. Either add IT to 921 or list ASTM C 595 in section 2.1 - I understand the thought of removing the words "Course" from the title of section 2.4 because a fine aggregate was introduced for internal curing. However, section 2.4 has become convoluted with only a reference to lightweight fine aggregate and not normal fine aggregate. Maybe add a simple sentence stating the default fine aggregate is silica sand?

Response:
