

5220400 CONCRETE SIDEWALK AND DRIVEWAYS
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Ananth Prasad
w (850) 942-1405
aprasad@ftba.com

Comments: (Internal 11-30-21 sent as comment within review for 5200100)

- Specification Section 120 – Excavation & Embankment, does NOT require compaction of native materials for construction in cut sections. Compaction requirements are for fill areas only. Lift thicknesses for fill are outlined in the Specification Section 120.
- There is no need to change or regurgitate the spec in Section 522. It should be determined by the material being used in the embankment, just as it is under the roadway.

Response:
