

5240100 Concrete Ditch and Slope Pavement
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Ananth Prasad
w (850) 942-1405
aprasad@ftba.com

Comments: (11-15-21 Internal)

Good afternoon, 524-1 needs to reference the design plans and standard plans. Design plans were removed. See below for a recommendation. Also, 524-5.4 change isn't needed. The Standard plans already says to install filter fiber on all ditch pavement except for MAP.

524-1 Description.

Construct concrete pavement in the flow channel of drainage ditches and on slopes **as shown on the Plans and in accordance with Standard Plans.**

Response:

Change was incorporated prior to industry review.
