

EXPECTED IMPLEMENTATION JULY 2022

GROUNDING AND LIGHTNING PROTECTION

(REV 11-10-21) (FA 1-6-22) (7-22)

SUBARTICLE 620-3.2.2 is deleted and the following substituted:

620-3.2.2 Minimum Resistance Not Required: Install a single ground rod assembly for the following applications. No resistance to ground measurements are required.

1. Conventional lighting
2. External lighting for signs
3. Signal cable & span wire
4. Aerial interconnect messenger wire
5. Pedestals for pedestrian signals
6. Pull boxes with metal covers when 120 volts (or greater) AC power is present
7. Splice boxes with wire grounding units.