

6460000 ALUMINUM POLES, PEDESTALS, AND POLES
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Sarah Smith
(850) 414-4776
Sarah.smith@dot.state.fl.us

Comments: (12-7-21, Industry)

Why didn't the contract language for the Transformer Base stay in Section 646? Section 965 is for Materials and APL information.

Response: The Division II language is written to the Contractor. The transformer base materials requirements above are written to the manufacturer; Section 965 (Division III) is the appropriate place for this language.

We are attempting to separate contractor requirements (Division II) from manufacturer requirements (Division III) throughout the book.
