

7151800 HIGHWAY LIGHTING SYSTEM
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Stephen Furman

Work Phone: 850-981-2712

E-Mail: Stephen.Furman@dot.state.fl.us

Comments: (11-15-21 Industry)

The additions to this spec. seem out of place in the number 7 comment. I suggest making the additions number 8 under "High Mast Lighting Pole and Foundation Removal".

Response:

Thank you for your comment. The revisions are in appropriate Section of the specification as removal is addressed under the pay items for "High Mast Lighting Pole Complete". No change made.