

9210000 Portland Cement and Blended Cement  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

---

Tim Counts  
Office - (352) 955-6651  
tim.counts@dot.state.fl.us

Comments: (6-28-22 Industry)

During the internal review of one of our revisions we received some feedback on an area of the section that is not currently being revised. It's a suggestion to update the language to improve grammar and clarity, I've provided the specific request below. However, I am being told that grammar and wording changes should be at the prerogative of your office, and that our technical sections should focus on technical content. So, do you have any issues or concerns with this proposal coming from our office?

As-is:

921-6 Rejection of Material:

The entire container which holds cement that does not meet the requirements of this Section or has been damaged, is partially set, lumpy or caked shall be rejected. Bagged cement which varies more than 5% from the designated weight, or if the average weight of 50 sacks, taken at random, is less than the designated weight, the cement shall be rejected.

Proposed:

921-6 Rejection of Material:

Reject the entire container of cement if the it does not meet the requirements of this Section, including cement that has been damaged, partially set, lumpy, or caked.  
Reject bagged cement if it varies more than 5% from the designated weight, or if the average weight of 50 randomly-selected sacks is less than the designated weight.

Response:

\*\*\*\*\*