

**105 CONTRACTOR QUALITY CONTROL GENERAL REQUIREMENTS – COMPLIANCE WITH THE MATERIALS MANUAL.  
(REV 3-7-13) (FA 2-15-13) (7-13)**

SUBARTICLE 105-3.2 (Page 134) is deleted and the following substituted:

**105-3.2 Compliance with the Materials Manual.**

Producers of Flexible Pipe shall meet the requirements of Section 6.1, Volume II of the Department's Materials Manual, which may be viewed at the following URL:

<http://www.dot.state.fl.us/specificationsoffice/Implemented/URLinSpecs/Files/section61.pdf> .

Producers of Precast Concrete Pipe shall meet the requirements of Section 6.2, Volume II of the Department's Materials Manual, which may be viewed at the following URL:

<http://www.dot.state.fl.us/specificationsoffice/Implemented/URLinSpecs/Files/section62.pdf> .

Producers of Precast Concrete Drainage Structures shall meet the requirements of Section 6.3, Volume II of the Department's Materials Manual, which may be viewed at the following URL:

<http://www.dot.state.fl.us/specificationsoffice/Implemented/URLinSpecs/Files/section63.pdf> .

Producers of Precast/Prestressed Concrete Products shall meet the requirements of Sections 8.1 and 8.3 of the Department's Materials Manual, which may be viewed at the following URLs:

<http://www.dot.state.fl.us/specificationsoffice/Implemented/URLinSpecs/Files/section81.pdf> .

<http://www.dot.state.fl.us/specificationsoffice/Implemented/URLinSpecs/Files/section83.pdf> .

Producers of Precast Prestressed Concrete Products using Self Consolidating Concrete shall meet the requirements of Section 8.4, Volume II of the Department's Materials Manual, which may be viewed at the following URL:

<http://www.dot.state.fl.us/specificationsoffice/Implemented/URLinSpecs/Files/section84.pdf>

Producers of Incidental Precast/Prestressed Concrete Products shall meet the requirements of Section 8.2, Volume II of the Department's Materials Manual, which may be viewed at the following URL:

<http://www.dot.state.fl.us/specificationsoffice/Implemented/URLinSpecs/Files/section82.pdf> .

Producers of Portland Cement Concrete shall meet the requirements of Section 9.2, Volume II of the Department's Materials Manual, which may be viewed at the following URL:

<http://www.dot.state.fl.us/specificationsoffice/Implemented/URLinSpecs/Files/section92.pdf> .

Producers of Structural Steel and Miscellaneous Metal Components shall meet the requirements of Sections 11.1, 11.2, 11.4 and 11.5 of the Department's Materials Manual, which may be viewed at the following URLs:

<http://www.dot.state.fl.us/specificationsoffice/Implemented/URLinSpecs/Files/section111.pdf> .

<http://www.dot.state.fl.us/specificationsoffice/Implemented/URLinSpecs/Files/section112.pdf> .

<http://www.dot.state.fl.us/specificationsoffice/Implemented/URLinSpecs/files/Section114.pdf>

<http://www.dot.state.fl.us/specificationsoffice/Implemented/URLinSpecs/files/Section115.pdf>

SUBARTICLE 105-8.8 (Page 140). The title of the Subarticle is deleted and the following substituted:

**105-8.8 Supervisory Personnel – Post-Tensioned and Movable Bridge Structures:**

SUBARTICLE 105-8.8.7.1 (Page 143) is deleted and the following substituted:

**105-8.8.7.1 Post-Tensioning:** Perform all PT field operations under the direct supervision of a Level II CTQP Qualified PT Technician who must be present at the site of the post-tensioning work during the entire duration of the operation. For the superstructures of bridges having concrete post-tensioned box or I girder construction, provide at least two CTQP qualified PT technicians, Level I or II, on the work crew. The supervisor of the work crew, who must be a Level II CTQP Qualified PT Technician, may also be a work crew member, in which case, the supervisor shall count as one of the two CTQP qualified work crew members. For PT operations other than the superstructures of post-tensioned box or I girder construction, perform all PT operations under the direct supervision of a Level II CTQP Qualified PT Technician who must be present at the site of the PT work during the entire duration of the operation. Work crew members are not required to be CTQP qualified.

SUBARTICLE 105-8.8.7.2 (Pages 143 - 144) is deleted and the following substituted:

**105-8.8.7.2 Grouting:** Perform all grouting field operations under the direct supervision of a Level II CTQP Qualified Grouting Technician who must be present at the site of the grouting work during the entire duration of the operation. For the superstructures of bridges having concrete post-tensioned box or I girder construction, provide at least two CTQP qualified grouting technicians, Level I or II, on the work crew. The supervisor of the work crew, who must be a Level II CTQP Qualified Grouting Technician, may also be a work crew member, in which case, the supervisor shall count as one of two CTQP qualified work crew members. For grouting operations other than the superstructures of post-tensioned box or I girder construction, perform all grouting operations under the direct supervision of a Level II CTQP Qualified Grouting Technician who must be present at the site of the grouting work during the entire duration of the operation. Work crew members are not required to be CTQP qualified.

Perform all vacuum grouting operations under the direct supervision of a crew foreman who has been trained and has experience in the use of vacuum grouting equipment and procedures. Submit the crew foreman's training and experience records to the Engineer prior to performing any vacuum grouting operation.