

ADVANCED TRANSPORTATION CONTROLLER ACCESSORIES – ADVANCED TRANSPORTATION CONTROLLER CABINET.

(REV 2/13/24)

ARTICLE 678-2 is deleted and the following substituted:

678-2 Materials.

Meet the following requirements:

Conflict Monitor*	Section 995
Malfunction Management Unit*	Section 995
Power Supply*	Section 995
Load Switch*	Section 995
Flasher*	Section 995
Flash Transfer Relay	NEMA TS2-2021, Section 6.4
Model 206L Power Supply Unit*	Section 995
Model 208 Monitor Unit*	Section 995
Model 210 Monitor Unit*	Section 995
Power Distribution Assembly*	Section 995
Input File*	Section 995
Model 430 Flash Transfer Relay.....	CALTRANS TEES 2020, 6.4.5.1.5
Time Switch*	Section 995
Serial Interface Unit (Model 2218)*.....	Section 995
High Density Switch Pack/Flasher Unit (Model 2202-HV)*	Section 995
High Density Switch Pack/Flasher Unit (Model 2202-LV)*	Section 995
Cabinet Monitor Unit (Model 2212-HV)*	Section 995
Cabinet Monitor Unit (Model 2212-LV)*	Section 995
Auxiliary Display Unit (Model 2220)*.....	Section 995
Flash Transfer Relay Unit *	Section 995
Cabinet Power Supply (Models 2216-24-HV, 2216-2412-HV, 2217, 2248)*	Section 995

*Use products listed on the Department’s APL.

Do Not Use Without CO Specs Authorization