
Index 310 Concrete Sidewalks

ORIGINATION

Date: March 8, 2017

Name: Derwood Sheppard

Phone: (850) 414-4334

Email: derwood.sheppard@dot.state.fl

COMMENTARY

Sheet 1: Clarified Joints in the Curb Ramps in the call outs in the SIDEWALK Plan views.

COMMENTS AND RESPONSES

BLACK = Industry Review Comments **RED** = Standard Plans Response

Name: Karina Fuentes, P.E.

Date: Monday, September 25, 2017 5:30 PM

COMMENT:

Suggest to revise note 1 as follows: "Use 6-in. THICK concrete for sidewalks and curb cut ramps within CURBED returns (see Plan view). Also use 6-in. thick concrete for sidewalks located within corner returns on flush shoulder roadways and for sidewalks across turnouts."

RESPONSE:

Date: 9/26/17

The usage of 6" thick concrete was coordinated with Construction, Design, and Maintenance. The result was standardizing the use of 6" concrete only in the radial returns of curbed roadways. However, we will coordinate further with consideration for including the suggestion in the future.