


STAIR TREAD AND RISER DETAILS

* The greatest riser height within the flight of steps shall not exceed the smallest by more than 3/8".

** The greatest tread depth within the flight of steps shall not exceed the smallest by more than 3/8".

- NOTES:**
- Do not use this Index for suspended (structural) steps or stairways.
 - Construct steps in accordance with Section 522 of the FDOT Standard Specifications.
 - Concrete: Class I, Specification 347.
 - Reinforcing Steel: Grade 60, ASTM A615.
 - Tread Finish: Broom finish parallel to steps unless otherwise shown in Plans.
 - Pedestrian Railing: See Index Nos. 850, 860, 870, 880 or Project Specific Design.
 - Cost of concrete steps, landings and cheekwalls shall be paid for under the contract unit price for Class I Concrete (Miscellaneous), C.Y. Cost of reinforcing steel shall be paid for under the contract unit price for Reinforcing Steel (Miscellaneous), L.B.

REVISIONS			
DATE	BY	DESCRIPTION	DATE
01/01/07	JEH	New Design Standard issued.	



2006 Interim Design Standard

CONCRETE STEPS

Interim Date	Sheet No.
01/01/07	1 of 1
Index No.	
521	