




ELEVATION

**ALTERNATE STRAND PATTERNS**

- 8 ~ 0.6" Ø, CFRP 7-Strand, at 24 kips
- 8 ~ 1/2" Ø, CFRP Single-Strand, at 23.5 kips



**SECTION D-D**  
(See Nondrivable Unforeseen Reinforced Precast Pile Build-Up Detail)



**SECTION E-E**  
(See Drivable Unforeseen Prestressed Precast Pile Splice Detail)

**CFRP PILE SPLICE REINFORCEMENT DETAILS**


**NOTES:**

1. Work this Index with Index No. 22600 - Notes and Details for Square CFRP & SS Prestressed Concrete Piles and Index No. 22601 - Square CFRP & SS Prestressed Concrete Pile Splices.
2. Any of the given Alternate Strand Patterns may be utilized. The strands shall be located as follows:  
Place one strand at each corner and place the remaining strands equally spaced between the corner strands. The total strand pattern shall be concentric with the nominal concrete section of the pile.

**CFRP PRESTRESSED PILE DETAILS**

12/17/2015 2:15:38 PM


LAST REVISION 01/01/16	REVISION	DESCRIPTION:	<b>FY 2016-17 DESIGN STANDARDS</b>	<b>12" SQUARE CFRP &amp; SS PRESTRESSED CONCRETE PILE</b>	INDEX NO. <b>22612</b>	SHEET NO. <b>1 of 2</b>
---------------------------	----------	--------------	----------------------------------------	---------------------------------------------------------------	---------------------------	----------------------------




ELEVATION

**STRAND PATTERN**

8 ~ 1/2" Ø, HSSS at 24 kips




SECTION A-A



SECTION D-D

(See Nondrivable Unforeseen Reinforced Precast Pile Build-Up Detail)



SECTION E-E

(See Drivable Unforeseen Prestressed Precast Pile Splice Detail)

**SS PILE SPLICE REINFORCEMENT DETAILS**

**NOTES:**


1. Work this Index with Index No. 22600 - Notes and Details for Square CFRP & SS Prestressed Concrete Piles and Index No. 22601 - Square CFRP & SS Prestressed Concrete Pile Splices.
2. Any of the given Strand Patterns may be utilized.

The strands shall be located as follows:

Place one strand at each corner and place the remaining strands equally spaced between the corner strands. The total strand pattern shall be concentric with the nominal concrete section of the pile.

**SS PRESTRESSED PILE DETAILS**

12/17/2015 2:15:39 PM

LAST REVISION 01/01/16	DESCRIPTION:	 <b>FY 2016-17 DESIGN STANDARDS</b>	<b>12" SQUARE CFRP &amp; SS PRESTRESSED CONCRETE PILE</b>	INDEX NO. <b>22612</b>	SHEET NO. <b>2 of 2</b>
---------------------------	--------------	------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------	---------------------------	----------------------------