

308 Summary of Drainage Structures and Optional Materials Tabulation

308.1 General

The Summary of Drainage Structures sheet shows the location, size, length, number and type of drainage structures used in a project. The sheet format is available in the FDOT CADD Software. Specific levels and fonts are in the [CADD Manual](#).

See **Exhibit 308-1** for an illustration of the Summary of Drainage Structures sheet.

The Optional Materials Tabulation sheet is included when providing acceptable options for pipe material and sizes that will satisfy the Design Service Life. The sheet format is available in the FDOT CADD Software.

See **Exhibits 308-2** and **308-3** for illustrations of Optional Materials Tabulation sheets.

308.2 Summary of Drainage Structures

Prepare and include a summary of drainage structures in the plans. List the structures in numerical order of structure number. Identify the location of each structure by station along the centerline of construction.

Tabulate storm and cross drains in the summary of drainage structures by structure number, providing the station, size, length and incidental quantities appropriate for the material detailed in the plans. When the number of columns exceeds one page, the additional sheet is to be numbered using a suffix (e.g., 3 and 3A, 4 and 4a). Information for the drainage elements in the columns is obtained from drainage structure sheets and plan-profile sheets. The order in which the elements are listed should be as follows:

- | | |
|----------------------------|---------------------------|
| (1) Pipe Sizes for | (6) Gutter Inlets |
| (a) Storm and Cross Drains | (7) Flared End Sections |
| (b) Gutter Drain | (8) Mitered End Sections |
| (2) Curb Inlets | (9) Performance Turf, Sod |
| (3) Manholes | (10) Class of Concrete |
| (4) Junction Boxes | (11) Reinforcing Steel |
| (5) Ditch Bottom Inlets | (12) Riprap |


Use the "Description" column to specify the type of structure, the outgoing pipe and the end treatment of that pipe, if applicable.

The remarks column contains special notes pertaining to the structure. The "Final Quantity" line is for construction to use and must be left blank.

It is recommended that structure numbers be established using the convention shown in the exhibits and described as follows:


- (1) For simple cross drains, one structure number is appropriate for the inlet, pipe and outlet treatments.

Example #1 (cross drain w/o median inlet)



- (2) For complex cross drains, it is suggested that the first and all intermediate structure numbers identify the hydraulically upper end treatment and pipe. The last structure number should identify the hydraulically upper end treatment, pipe and hydraulically lower end treatment.

Example #2 (Double pipe cross drain and median inlet)



308.3 Optional Materials Tabulation

Optional culvert materials must be considered for all culverts; however, culvert extensions and end section replacements are to match the existing culvert material. See Chapter 8 of the [Drainage Design Guide](#) for more information.

Conduct an Optional Pipe Materials Analysis and prepare an Optional Materials Tabulation sheet to be placed in the plans.

The Optional Material Tabulation sheet is to include:

- (1) Structure number, or description
- (2) Design service life (DSL)
- (3) Size
- (4) Material and thickness or class, corrugation requirements, protective coating

Modification for Non-Conventional Projects:

Delete **FDM 308.3** and see **Chapter 6** of the [Drainage Manual](#) for Optional Material requirements. Designate installed material on the Optional Materials Sheet, Summary of Drainage Structures, or on the as-built plan view.

THIS EXAMPLE SHOULD BE USED WHEN PIPE FLOW LINES, AND/OR SIZES FOR INDIVIDUAL OPTIONS ARE NOT THE SAME (SEE STRUCTURE NO. 14) OR WHEN NUMEROUS EXCEPTIONS OCCUR.

STR. NO.	DSL YEARS	SIZE (Inches)	PLOTTED	MATERIAL & THICKNESS	FL	FL	AS BUILT	REMARKS
1	100	18	X	RCP CLASS II				
2	100	18	X	RCP CLASS II				
3	100	15	X	RCP CLASS II SRAP	7.0			
4	100	36	X	RCP CLASS II SRSP, 12 GA. SRAP, 12 GA. SRASP, 16 GA.	5.7			
5	100	15	X	RCP CLASS II SRAP	7.7			
6	100	36	X	RCP CLASS II SRSP, 12 GA. SRAP, 12 GA. SRASP, 16 GA.	6.4	5.7		
7	100	36	X	RCP CLASS II	6.5	6.4		
8	100	42	X	RCP CLASS II SRAP SRSP	7.9	7.7		
9	100	30	X	RCP CLASS II SRAP, 16 GA. SRSP, 16 GA.	6.8	6.5		
10	100	18	X	RCP CLASS II SRAP, 16 GA. SRSP, 14 GA. SRASP, 16 GA.	7.6	7.2		
11	100	18	X	RCP CLASS II SRAP, 16 GA. SRSP, 14 GA. SRASP, 16 GA.	8.0	7.6		
12	100	24	X	RCP CLASS III				ENDWALL
13	100	24x38 35x24	X	ERCPC CLASS II ASPA, 14 GA.	10.4	10.3		
14	50	30	X	RCP CLASS III SRASP 14 GA. SRAP, 14 GA. HDPE-1 PVC	6.0	5.9		
		36		CAP, 16 GA.	5.9	5.8		
		36		CSP, 16 GA. BIT. COATED	5.9	5.8		
14A	50	19x30 28x20	X	ERCPC CLASS III ASPA 14 GA.	5.9	5.8		

Exhibit 308-2
Date: 1/1/15

REVISIONS				LUKE S. WALKER, P.E. P.E. NO.: 99991 ROADWAY ENGINEERS, INC. 123 MAIN STREET TALLAHASSEE, FL 32301	STATE OF FLORIDA DEPARTMENT OF TRANSPORTATION			OPTIONAL MATERIALS TABULATION	SHEET NO.
DATE	DESCRIPTION	DATE	DESCRIPTION		ROAD NO.	COUNTY	FINANCIAL PROJECT ID		
					SR 22	BAY	123456-1-52-01		

