

## **460 STRUCTURAL STEEL AND MISCELLANEOUS METALS.**

**(REV 4-3-01) (FA 4-11-00) (7-01)**

SUBARTICLE 460-2.1 (Page 600) is deleted and the following substituted:

**460-2.1 General:** Meet the material requirements of Section 502 and Division III, with specific reference to Sections 961 through 964.

Except where otherwise shown in the plans, use structural steel for all major members, and rivet steel for all rivets. Use either cast steel or cast iron for castings, as shown in the plans.

Field install all shear connectors which are located on the top flange of steel girders and beams after the deck forms are in place. Do not install top flange shear connectors at the fabrication plant. Install all shear connectors, regardless of location, in accordance with Section 502.

For paint, meet the requirements of Section 971.

ARTICLE 460-34 (Page 617) is expanded by the following:

Field install top flange shear connectors, at locations shown in the Contract Documents, in accordance with Section 502.