



**Judy F Frazier**  
01/06/2003 03:08 PM

To: John H Owens/CO/FDOT@FDOT  
cc:  
cc:  
Subject: Re: D2340010.D01

Dennis J Barber



**Dennis J Barber**  
01/06/03 01:36 PM

To: David Chason/CO/FDOT@FDOT  
cc:  
Subject: Re: D2340010.D01 

Response to Bob Burleson

The spec allows for a thickness adjustment. Instead of cores, it will be based on the overall spread rate which in reality is a thickness adjustment. It also allows for plan changes due to it being a plan quantity item. Any plan changes as directed by the Engineer would be added or deducted.

Dennis Barber  
State Construction Office  
User I.D. CN982DB  
E-mail Address [dennis.barber@dot.state.fl.us](mailto:dennis.barber@dot.state.fl.us)  
Ph. No. (850) 414-4177  
SC 994-4177