



Richard J Kessler
11/05/2002 01:33 PM

To: John H Owens/CO/FDOT@FDOT
cc: Susan Blazo/SM/FDOT@FDOT, Rodney Powers/SM/FDOT@FDOT
cc: Susan Blazo/SM/FDOT@FDOT, Rodney Powers/SM/FDOT@FDOT
Subject: Re: Industry review of the following: D3000084 - Application of
Tack Coat - Rate of Application and D9750000 - Elastomeric
Coating System.

Rodney Powers
11/04/2002 01:16 PM

To: Richard J Kessler/SM/FDOT@FDOT
cc:
Subject: Re: Industry review of the following: D3000084 - Application of
Tack Coat - Rate of Application and D9750000 - Elastomeric
Coating System. 

Rick,

Requiring ISO 9000 Standard might make it impossible to get the coating. Perhaps should
allow alternate means of quality control acceptable to the Department .

Rod

Rodney G. Powers
Assistant State Corrosion Engineer
Florida Department of Transportation
2006 N.E. Waldo Road
Gainesville, Florida 32609
Tel. 352-337-3134; SunCom 642-3134
FAX 352-334-1649
E-Mail rodney.powers@dot.state.fl.us
Richard J Kessler

*no change
other vendors already
have ISO cert.
RJR*



Robert Robertson
12/04/02 10:49 AM

To: Shirley Harvey/CO/FDOT@FDOT
cc:
Subject: Re: Spec. Review Change, D9750000

The answer to his question is no. The product is required to be on the QPL and thus will be pre-approved. Certification is all that is required at the project level.

Robert Robertson
FDOT Tallahassee Structures
SC 994-4267
(850) 414-4267
Shirley Harvey



Shirley Harvey
12/04/02 09:28 AM

To: Robert Robertson/CO/FDOT@FDOT
cc:
Subject: Spec. Review Change, D9750000

I am forwarding a late comment that was sent to Duane. If you have any questions please call.
Thanks,

shirley harvey
SC 994-4120
(850)414-4120
shirley.harvey@dot.state.fl.us
----- Forwarded by Shirley Harvey/CO/FDOT on 12/04/02 09:33 AM -----



Clinton Shaw
12/04/02 08:28 AM

To: Shirley Harvey/CO/FDOT@FDOT
cc:
Subject: Spec. Review Change, D9750000

Shirley,
I am posting this in the comments folder. It's a little late, use it if you can.

Thanky

Clinton J. Shaw
(850) 414-4129 SC 994-4129
Clinton.Shaw@dot.state.fl.us
----- Forwarded by Clinton Shaw/CO/FDOT on 12/04/2002 08:30 AM -----



Duane F Brautigam
12/04/2002 07:23 AM

To: Clinton Shaw/CO/FDOT@FDOT
cc:
Subject: Spec. Review Change, D9750000

Duane F. Brautigam, P.E.
State Specifications Engineer
Florida Department of Transportation
(850) 414-4130; SC 994-4130
duane.brautigam@dot.state.fl.us
----- Forwarded by Duane F Brautigam/CO/FDOT on 12/04/2002 07:23 AM -----



Carlos Bermudez
12/03/2002 10:49 AM

To: Duane F Brautigam/CO/FDOT@FDOT
cc:
Subject: Spec. Review Change, D9750000



Received this question after the due date but I'm sending for clarification.

Under 975-2, Certification, it is directed to provide a 'written certification from the manufacturer that the product meets the requirements of this section.' The question is if we want a shop drawing or submittal for this item?

Carlos W. Bermudez
District 4 Construction
954-777-4188, SC 436-4188