

400 CONCRETE STRUCTURES – MATERIALS.

(REV 4-22-03) (FA 5-15-03) (1-04)

SUBARTICLE 400-5.7.2 (Page 338) is deleted and the following substituted:

400-5.7.2 Materials: Fabricate permanent stay-in-place metal forms and supports from steel meeting the requirements of ASTM A 653 [ASTM A 653M] having a coating designation G165 [Z500]. Do not use form materials that are less than 22 gauge [0.7925 mm] in thickness.