

**120 EXCAVATION AND EMBANKMENT-COMPACTION OF SUBGRADE.  
(REV 5-24-04) (FA 5-25-04) (1-05)**

SUBARTICLE 120-9.4 (Page 156) is deleted and the following substituted:

**120-9.4 Compaction of Subgrade:** If the plans do not provide for stabilizing, compact the subgrade (as defined in 1-3) in both cuts and fills to the density specified in 120-10.2. For undisturbed soils, do not apply density requirements where constructing narrow widening strips or paved shoulders 5 feet [1.5 m] or less in width.

Where trenches for widening strips are not of sufficient width to permit the use of standard compaction equipment, perform compaction using vibratory rollers, trench rollers, or other type compaction equipment approved by the Engineer.

Maintain the required density until the base or pavement is placed on the subgrade.