

RESPONSE TO COMMENTS RECEIVED

BOB DION

File: 5201206 - Asphalt Curb Pad
Username: bob dion
UserEmail: bob_dion@urscorp.com
UserTel: (386) 740-0665
Date: Tuesday, May 10, 2005
Time: 11:50:28 AM

Comments:

Suggest changing 'called for' in 520-12.6 to 'detailed in the plans' or 'as detailed in the plans'.
Either that or add the dimensions of the curb pad. A recurring comment made during plans reviews is to ask for the depth to be shown.

RESPONSE

The designer should already be providing a depth/thickness for the asphalt curb pad. If not this should be addressed with the District Design Engineer. Called for in 520-12.6 is fine as is, not needed to be detailed in the plans. Design Standards show the dimensions of the curb/curb & gutter.

Gene Strickland

File: 5201206 - Asphalt Curb Pad
Username: Gene Strickland
UserEmail: genes@andersoncolumbia.com
UserTel: 850-526-4440 x305
Date: Tuesday, May 17, 2005
Time: 08:14:06 AM

Comments:

A Pay Item Note should be included in the plans when this work is required.

RESPONSE

The reason for the specification modification to include the asphalt curb pad, is to eliminate the pay item footnote which is supposed to be inserted by the designer currently which is doesn't occur. No change.