

COMMENTS RECEIVED FROM INDUSTRY REVIEW

Jody Wall

I like the inclusion of the AASHTO M-195 specification but it should not be limited to the 3/4 inch (19 mm) gradation. Depending on the area of the state and the concrete producer the gradation might be any of the 3 specified gradations of M-195. They are 3/4", 1/2" and 3/8".

Thanks Jody

Jody R.Wall, P.E.
jwall@stalite.com
Director of Research and Development
Quality Control Manager
Carolina Stalite Company