

Comments Received From Industry Review

David Bremer

File: 5270000 - Detectable Warnings on Walking Surfaces
Username: David Bremer
UserEmail: gulf8@earthlink.net
UserTel: 850/514-1937
Date: Thursday, November 03, 2005
Time: 09:29:05 AM

Comments:

Unless it is the intent to limit to the colors listed, I suggest changing 527-2.3 to "...
Acceptable colors include: ... "

Bob Dion

File: 5270000 - Detectable Warnings on Walking Surfaces
Username: Bob Dion
UserEmail: bob_dion@urscorp.com
UserTel: 386-740-0665
UserFAX: 386 740-1275
Date: Monday, November 07, 2005
Time: 12:53:14 PM

Comments:

527-2.1.2 Expand the first paragraph by adding a sentence at it's beginning: 'Use
Detectable Warnings applied as a secondary application to cured concrete only.'

Suggest deleting the second paragraph. It is not needed. The references in it to the QPL
for should be included in 527-2.4.

527-2.4 Shouldn't the added paragraph also apply to preformed material? If so, suggest
deleting 'In addition, for field formed products'. Make this a requirement of both or
delete the paragraph, Index 304 list the criteria to be met. It would seem that repairs to
preformed materials could also be needed.



Florida Department of Transportation

JEB BUSH
GOVERNOR

605 Suwannee Street
Tallahassee, FL 32399-0450

DENVER J. STUTLER, JR.
SECRETARY

MEMORANDUM

DATE: November 3, 2005
TO: Specification Review Distribution List
FROM: Duane F. Brautigam, P.E., State Specifications Engineer
SUBJECT: Proposed Specifications Change: 5270000 - Detectable Warnings on Walking Surfaces

In accordance with Specification Development Procedures, we are sending you a copy of a proposed specification change to Section 527.

This change was proposed by Dean Perkins of the State Structures Design Office to allow the use of formed-in-place materials.

Please share this proposal with others within your responsibility. Review comments are due within four weeks and should be sent to Mail Station 75 or to my attention via e-mail at SP965DB or duane.brautigam@dot.state.fl.us. Comments received after December 1, 2005 may not be considered. Your input is encouraged.

DFB/jf

Attachment

COMMENTS: 527-2.4 Submit typical material safety data sheet for all applicable materials for use by the Department. The Department should review material hazards.

527-3.1 Ensure that installations are made in accordance with all safety and health requirements indicated on manufacturers material safety data sheets.

Submitted by: Bob Miller

Phone #: 813 241 6148