

4710000 Comments Received from Industry Review

Ghulam Mujtaba

June 2006

1. Page 1, 471-3, Paragraph 1, Sentence 1
 1. Define "...extreme heat or impact."

2. Page 1, 471-3, Paragraph 1, Last Sentence
 1. This indicates that the damages at the manufacturing plant may be accepted. Change to read in an active voice: "Department will reject the damaged structural plastics."

3. Page 1, 471-3, Paragraph 2
 1. Change the passive voice sentences to active voice. In lieu of "...will be rejected." Change to "...Department will reject."

Bob Dion

File: 4710000-Plastic Fender System Components
Username: Bob Dion
UserEmail: bob_dion@urscorp.com
UserTel: 386-740-0665
UserFAX: 386 740-1275
Date: Monday, July 17, 2006
Time: 02:47:17 PM

Comments:

Delete the second sentence in the last paragraph of 471-3, dealing with cutting off piles. There is a specification out for review, 4550400, that includes the same language. Add 'for Plastic Fender System Components' to the first paragraph of 471-5 after Price and payment. Delete the second paragraph of 471-5. Payment for composite piling is addressed in the modification to section 455 mentioned above.