

9810000 INDUSTRY REVIEW COMMENTS

Ray Haverty

COMMENT:

981-3.2 Dimensions:

Within this section the measurements are given in English and (Metric) dimensions,
is this correct or should it be English Only?

Anthony Walsh

COMMENTS:

First Paragraph: The contractor is directed to shade the sod from the time it is cut until it is planted. This would entail covering transports from the sod fields as well as individual covers for pallets spot placed along a project. What are the repercussions if the sod is not continually shaded? I see this as very unenforceable.

Second Paragraph: I would suggest striking the reference to the source of sod being inspected and approved by the Engineer prior to being cut for use in the work. This is unnecessary considering the acceptance conditions of the Section 570 Performance specification.
