

**4460300 – EDGEDRAIN (DRAINCRETE)  
COMMENTS FROM INDUSTRY REVIEW**

\*\*\*\*\*

Bob Dion  
URS Corp – (386)740-0665

**Comments:**

Suggest rewording the 1st sentence of 446-5.1 after 'and' to 'determine the drain rate in accordance with FM 5-570.', if your intent is to take the samples and test them in accordance with FM 5-570, since it addresses both.

\*\*\*\*\*

Ghulam Mujtaba  
State Materials Office

**Comments:**

In the proposed document it has been mentioned that the Engineer will take QC sample. I recommend that the Contractor should take the QC sample or change the wording of "QC sample" to Verification Sample, QA Sample, or just Sample.