

4460300 – EDGEDRAIN (DRAINCRETE)
RESPONSE TO COMMENTS FROM INDUSTRY REVIEW

Bob Dion
URS Corp – (386)740-0665

Comments:

Suggest rewording the 1st sentence of 446-5.1 after 'and' to 'determine the drain rate in accordance with FM 5-570.', if your intent is to take the samples and test them in accordance with FM 5-570, since it addresses both.

Response: Agree will revise 446-5.1

Ghulam Mujtaba
State Materials Office

Comments:

In the proposed document it has been mentioned that the Engineer will take QC sample. I recommend that the Contractor should take the QC sample or change the wording of "QC sample" to Verification Sample, QA Sample, or just Sample.

Response: Agree will change the language to indicate sample. “A minimum of two test cylinders will be made for each LOT. A LOT represents one day’s production of each mix design”