

**9290000- POZZOLANS AND SLAG  
COMMENTS FROM INDUSTRY REVIEW**

\*\*\*\*\*

**Daniel F Haldi**  
daniel.haldi@dot.state.fl.us  
386-740-3516

**Comments:**

Section 1.1, last para: Repulpable bags ... degradation during mixing and before discharge of CHANGE TO "cementitious material mixture". Demo may / could be other than concrete ... why not grout, mortar, etc. It is as acceptable to the Engineer!  
-6: Ultra Fine Fly Ash should follow reg. Fly Ash -3, (Consistency with other material spec sections); then Silica -4, Metakaolin -5.  
End of Comments, Thank-you.

\*\*\*\*\*