

**9290000- POZZOLANS AND SLAG
RESPONSE TO COMMENTS FROM INDUSTRY REVIEW**

Daniel F Haldi

daniel.haldi@dot.state.fl.us

386-740-3516

Comments:

Section 1.1, last para: Repulpable bags ... degradation during mixing and before discharge of CHANGE TO "cementitious material mixture". Demo may / could be other than concrete ... why not grout, mortar, etc. It is as acceptable to the Engineer!

Response: Will incorporate the change

-6: Ultra Fine Fly Ash should follow reg. Fly Ash -3, (Consistency with other material spec sections); then Silica -4, Metakaolin -5.

Response: Since the UFFA is considered a highly reactive pozzolan with some specific requirements we felt it was easier to put this as a stand alone material Metakaolin or SF. No change incorporated.

End of Comments, Thank-you.