

EXPECTED IMPLEMENTATION JANUARY 2008

D

**400 CONSTRUCTION JOINTS-JOINTS IN SEA WATER OR BRACKISH WATER.
(REV 4-13-07) (FA 7-28-07) (1-08)**

SUBARTICLE 400-9.5 (Page 375) is deleted and the following substituted:

400-9.5 Joints in Sea Water or Brackish Water: For concrete placed in sea water or brackish water, do not place any construction joints between points 2 feet below the mean low water elevation and 6 feet above the mean high water elevation.

R

A

F

T