

**4070000-Three-Sided Precast Culvert
Response To Comments From Industry Review**

Bob Dion
bob_dion@urscorp.com
386 740-0665

Comments:

Recommend consolidating the requirements for obtaining precast structures from plants listed on the Departments list of Producers with Accepted Quality control Programs into 1 place, it is repeated in sections 407, 410 , 430 and 449 currently in industry review.

Response: That is the purpose of this change. 407, 410, 430 and 449 will only make mention of the general requirement. The details have been moved to Section105.

The revision to section 449 includes the same verbiage, however it does not mention a notarized statement, if needed suggest adding it to 449-1. Also, suggest deleting the 2nd and paragraphs of 407-1.

Response: The verbiage is repeated; however, the producers referenced in 430 may not be the same producers as 407. No change made

Add "Precast Concrete Drainage ProductsArticle 449-1' to 407-2.

Response: Change made.

Sam K. Joseph
Assistant District Materials & Research Engineer
(863) 519 – 4211

Comment

Revision date 10-15-07, Spec. #407-1, at the third paragraph, the last sentence should be modified to add “Quality Control” in front of the word “signed”.

Response: Change made.
