

5480700 RETAINING WALL SYSTEMS- ACCEPTANCE PROGRAM
COMMENTS FROM INDUSTRY REVIEW

Ray Haverty Jr
Email: ray.haverty@dot.state.fl.us
Tel:850-410-5531

Comments:

In 548-7.1 it states delete the requirement of 120-10.1.4.1, 120-10.4.3 ect... Then in 548-7.6.3 it reads will meet thr requirements of 120-10.4.3

Now my question how can this 120-10.4.3 be deleted and then ask the contractor to meet these requirements?

Carl Dempsey
Email: carld@andersoncolumbia.com
Tel: 386-752-4921
FAX: 386-752-6906

Comments:

548-7.2 Requires QC Density of 100%

548-7.4 Requires QC Density of 90% within 3 feet and 95% Beyond 3 feet Is the 100% density requirement an error?

If not, where is it to be applied?
