

EXPECTED IMPLEMENTATION JULY 2008

948 MISCELLANEOUS TYPES OF PIPE.

(REV 1-18-08) (FA 2-11-08) (7-08)

SUBARTICLE 948-1.7 (Pages 844 and 845) is deleted and the following substituted:

948-1.7 Polyvinyl Chloride (PVC) Pipe (12 to 48 Inches): Polyvinyl Chloride (PVC) Pipe for side drain, cross drain, storm drain and other specified applications shall conform to AASHTO M 278 for smooth wall PVC pipe, or AASHTO M 304 or ASTM F 949 for PVC ribbed pipe. Mitered end sections are not to be constructed of polyvinyl chloride. Use only concrete or metal mitered end sections as indicated in the Design Standards.

Provide certification of the actual mean diameter of pipe shipped to the project. Include in the certification the minimum and maximum diameters used to certify the actual mean diameter. The certification shall be attested to by a person having legal authority to bind the manufacturing company.

Ensure that the pipe joints have been tested at the plant hydrostatically at the specified pressure using test methods in ASTM D 3212 and witnessed by the Engineer.

SUBARTICLE 948-2.3.1 (Pages 845 and 846) is deleted and the following substituted:

948-2.3.1 General: Class I corrugated Polyethylene Pipe used for side drain, cross drain, storm drain or french drain shall meet the requirements of AASHTO M 294. Class II Corrugated Pipe shall meet the requirements of AASHTO M 294 and 948-2.3.1. Corrugations may only be annular; pipe conforming to the minimum cell classification 335400E may be used if the combination of color and UV stabilizer provides the same or better UV protection as 335400C. Mitered end sections are not to be constructed of polyethylene. Use only concrete or metal mitered end sections as indicated in the Design Standards.

Provide certification of the actual mean diameter of pipe shipped to the project. Include in the certification the minimum and maximum diameters used to certify the actual mean diameter. The certification shall be attested to by a person having legal authority to bind the manufacturing company.

Ensure that the pipe joints have been tested at the plant hydrostatically at the specified pressure using test methods in ASTM D 3212 and witnessed by the Engineer.

Obtain pipe products from producers listed on the Department's List of Qualified Flexible Pipe Manufacturing Plants, which may be viewed at the following: www.dot.state.fl.us/statematerialsoffice/quality/programs/qualitycontrol/materialslistings/sources/drainagesource.pdf.

Ensure that each shipment of products to the job site includes a list of products and each product has an affixed legible stamp mark of the plant, indicating its compliance with the requirements of the plant's Department approved Quality Control Plan and Contract Documents.

Accept responsibility of either obtaining products from another approved plant, or await re-approval of the plant, when the plant is removed from the Department's list of Flexible Pipe Manufacturing Plants.

The Engineer will not allow changes in Contract Time or completion dates as a result of the plant's loss of qualification. Accept responsibility for all delay costs or other costs associated with the loss of plant's qualification.