

4501201, Noncomplying Prestressed Products.

Comments from Industry Review

\*\*\*\*\*

**Greg Vickery**  
(850) 415-9529

Comments

The procedure states “when precast prestressed concrete products have been installed, the disposition of concrete cracks shall be in accordance with 400-21.” For beams, is this after all dead loads have been applied? Cracks in beams are evaluated by their location, width and length. Critical locations of cracks are any locations in which a crack would open under service loads or reduce the fatigued life. For piles, does 400-21 apply before driving and after driving?

\*\*\*\*\*