

4501604 PRECAST PRESTRESSED CONCRETE CONSTRUCTION _ ERECTION
RESPONSE TO COMMENTS FROM INDUSTRY REVIEW

Fred Ochoa

Comment;

Way to go! It's the contractor's means and methods as to how he will maintain stability on beams he has erected. It's the sensible solution.

Response:

No response is needed.

Greg Vickery
Office of the District Secretary
(850) 415-9529

Comment

Is section 450-16.4 needed? 450 is a specification for the pre-stress producers. They do not erect the products. Would 16.4 be more appropriate in Section 400?

Thank you for the opportunity to provide input. If you have any questions or need additional information, please do not hesitate to contact me at 850-415-9200.

Response:

The Section 450 is addressed to the Contractor. The specification covers requirements regarding fabrication, storage, transportation and erection of the precast/prestressed products. The subsection 450-16.4 is part of the Contractor's overall requirements and should be kept in Section 450.
