

9290102 – POZZOLANS AND SLAG – APPROVED LABORATORY
COMMENTS FROM INDUSTRY REVIEW

David Marshall
dmarshall@headwaters.com
352-365-6166

Comments:

I do not believe that this is a change to the specification, the certifying lab has had to be approved prior to this. Is there some other aspect of the revision that I am missing.

Our lab is CCRL and AMRL affiliated labs.

Ken Zinck (D5)
ken.zinck@dot.state.fl.us
386-740-3471

Comments:

Frank Kelch' comment:

Section 929-1.2 Approved Lab.

It says the lab has to be currently inspected but does not give a time frame on that. (6 Mo., 1 year, 2 year...) it is a gray area.

Ken Zinck
[Coordinating D5 comments]
ken.zinck@dot.state.fl.us
386-740-3471

Comments:

Diego Pagan's Comments 352-326-7727:

SUGGESTED CHANGE

929-1.2 Approved Laboratory: The cementitious materials supplier's testing laboratory must meet and maintain, at all times, the qualification requirements as described in 105-6 be currently inspected by the Cement and Concrete Reference Laboratory (CCRL), be actively participating in the CCRL proficiency program and have corrected all deficiencies that were noted at the time of inspection corrected. The producer's laboratory shall must authorize the inspecting laboratory, CCRL to send a copy of the final inspection report to the State Materials Office.

Thanks for the opportunity.
