

4000200, Concrete Structures
Comments From Industry Review

Paul Harkins
Construction Services Specialist
District One Construction
(863) 519-2226

Comment:

I do not have comments on the content of the above referenced specification change, however, I did notice that products to be listed on the QPL are identified by asterisks. As we had mentioned in some earlier emails on the QPL there is reference made to "Other References". I noticed that Section 400 is not referenced on the following QPL Numbers: S562, S932, S975

Anjani Girwarr
(863) 519-2825

Comment:

Why is this requirement being removed?
SUBARTICLE 400-2.6.6 (of the Supplemental Specifications) is deleted.

~~**400-15.2.6.6 Material Tests and Certification:** Before any portion of any shipment of finish coating is applied on the project, furnish the Engineer with a certificate from the manufacturer attesting that the commercial product furnished conforms to the same formula as that previously subjected to the tests specified in Section 975. In addition, submit the following product analysis, obtained from the manufacturer, for each batch of the material used:~~

- ~~(a) Weight per gallon.~~
- ~~(b) Consistency (Krebs Units).~~
- ~~(c) Weight percent pigment.~~
- ~~(d) Weight percent vehicle solids.~~
- ~~(e) Infra red spectra of vehicle solution.~~
