

4620200 POST-TENSIONING
COMMENTS FROM INDUSTRY REVIEW

Eddy Scott
D2 Specs/Design Review
386-961-7831
eddy.scott@dot.state.fl.us

Comments:

Shouldn't the URL to the referenced website be included in the Specification?

Response:

Bob Dion
386-740-0665
bob_dion@urscorp.com

Comments:

Suggest you add the URL address of the web site referred to in 462-2. Use 105-3.2 as an example of other FDOT URL addresses referred to in specifications.

Response:

Rodney Chamberlain
414-4276
rodney.chamberlain@dot.state.fl.us

Comments:

I recommend adding 31 strand systems to the following paragraph: Department standard tendon sizes for designing and detailing consist of 0.6 inch diameter strand in anchorages containing 4, 7, 12, 15, 19 and 27 strands; standard bar sizes from 5/8 to 1 3/4 inch diameter. Systems using alternate anchorage sizes and/or strands utilizing 1/2 inch strand and providing equivalent force to these standard sizes may be submitted for approval.

Response:

Duane Brautigam

Comments:

RUDY ... Please discard ... This change seems to be an overreaction to previous Please edit the second sentence of paragraph 2 Suggest adding to par. 7

Response:

Comments:

Response:

Comments:

Response:
