

4001103 CONCRETE STRUCTURES
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Jeffrey Pouliotte
850-410-5691
jeffrey.pouliotte@dot.state.fl.us

Comment: (5-27-10)

By eliminating the language in Subsection 400-11.3 and putting it in Sub-article 450-12.4, it seems that this language would no longer apply unreinforced elastomeric bearings that support cast-in-place flat slabs. This appears to be an oversight.

Response:
