

4001103 CONCRETE STRUCTURES  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

\*\*\*\*\*

Jeffrey Pouliotte  
850-410-5691  
[jeffrey.pouliotte@dot.state.fl.us](mailto:jeffrey.pouliotte@dot.state.fl.us)

Comment: (5-27-10)

By eliminating the language in Subsection 400-11.3 and putting it in Sub-article 450-12.4, it seems that this language would no longer apply unreinforced elastomeric bearings that support cast-in-place flat slabs. This appears to be an oversight.

Response: It is not an oversight since Specification 400-11.3 is intended to only apply to precast concrete components and **not** cast-in-place components. No changes made.

\*\*\*\*\*