

4100601 Precast Concrete Culvert
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Douglas Holdener
561.352.8959

dholdener@cemexusa.com

Comment: (7-21-10) We recommend keeping the criteria for lifting devices used in precast box culverts within the precast box culvert specification. In my experience in referencing FDOT specifications, the fewer pages and the fewer the number of specs you need to flip through results in better understanding and adherence of the specifications. I do not believe that cutting the language from Section 410 and pasting it in Section 450 will provide any greater assurance that it will be properly administered. The key to specification adherence is simplicity, comprehension, and enforcement. If the CEI, contractor, or manufacturer overlooks or does not understand the specification as it is written in Section 410, then logic suggests that they will continue to misunderstand or overlook the requirement even after it is relocated in Section 450. I suggest leaving the language in tact as it is written in Section 410 and not re-writing to reference 450. Instead of a spec change, I suggest that the FDOT remind CEIs and contractors in pre-work meetings of the need to fill lifting device blockouts with grout, and perhaps even include this task in the CEIs checklist of responsibilities.

Response:
