

4500902 Precast Prestressed Concrete Construction
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Mario A. Paredes, PE
352-955-6690
mario.paredes@dot.state.fl.us

Comment: (6-28-10) 450-9.2 should indicate the specific type of epoxy to use as there are many in 926.

Response: Agreed. See Response below.

Mario Paredes
352-262-6673
mario.paredes@dot.state.fl.us

Comments: (7-1-10) It seems to me that 926 only has one type of epoxy for this application, Type I. Why not indicate so in this specification like "926, type I". Is the intention that they can use other epoxies in some conditions that would require higher or lower viscosity or modulus? Or is the concern that the type may change letter assignment?

Response: Thank you for the comment. Per our phone conversation, we have determined that a Type F epoxy compound will be specified. Change made.
