

5570600 Vibratory Plowing – Basis of Payment  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

\*\*\*\*\*

Porr, Waldo  
Senior Contract Inspector  
(386) 740-3417

Comment: (6/2/10) With all the advancements of directional boring...I wouldn't consider vibratory plowing on any FDOT ROW. Vibratory plowing is a hit or miss and you can't control the direction of the bore and what you're about to bump or drill into.

Response: This will be considered in future changes. No changes made at this time.

\*\*\*\*\*

Chris Papastratis  
954-777-4193  
[Chris.Papastratis@dot.state.fl.us](mailto:Chris.Papastratis@dot.state.fl.us)

Comments: (6-18-10) We are not in favor of the proposed spec revision. The new spec is confusing on whether there is an initial payment after acceptance of the Plowing Path Report. Also, new spec does not specify % of payment for initial & Final payment or a guide to be used.

Response: References to final payment will be removed. Article 9-8.1 will be expanded to include submittal of as-built drawings.

\*\*\*\*\*