

635 PULL AND JUNCTION BOXES.
(REV 7-28-10) (FA 8-3-10) (1-11)

ARTICLE 635-3 (Page 749) is deleted and the following substituted:

635-3 Pull Boxes Installation.

Install pull boxes in accordance with the Design Standards, Index No. 17700. Ensure that the pull box cover is flush with the finished grade or sidewalk. Do not install pull boxes in roadways, driveways, parking areas, ditches or public sidewalk curb ramps.