

EXPECTED IMPLEMENTATION JULY 2011

522 CONCRETE SIDEWALK. (REV 7-29-10) (FA 9-20-10) (7-11)

SUBARTICLE 522-7.2 (Page 654) is deleted and the following substituted:

522-7.2 Surface Requirements: Provide the concrete with a broom finish. Ensure that the surface variations are not more than 1/4 inch under a 10 foot straightedge, or more than 1/8 inch on a 5 foot transverse section. Finish the edge of the sidewalk with an edging tool having a radius of 1/2 inch.