

0050104 CONTROL OF THE WORK  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

---

Tom Bowles  
941-757-0080  
[tom.b@russellengineering.com](mailto:tom.b@russellengineering.com)

Comments: (11-18-11)

The author needs to explain what he means by "..vertical displacements..".

Response:

\*\*\*\*\*

Marshall Dougherty  
863-370-4079  
[Marshall@rxengsol.com](mailto:Marshall@rxengsol.com)

Comments: (11-21-11)

I would like to suggest the following rewrite for the first sentence of the newly proposed Subarticle: "Submit shop drawings, and applicable calculations of the falsework system, including subsurface conditions and settlement estimates, to the Engineer of Record when vertical displacements are provided in the plans for falsework founded on shallow foundations, such as spread footings and mats." It provides more straight-forward direction to the contractor.

Response:

\*\*\*\*\*

D4 Construction

Comments: (12-15-11)

The origination form as I interpret it explains that the concern is excessive deflection/stress on the permanent structure due to settlement of falsework. Instead of focusing on the max displacement of the supports, would it be better to indicate the max. allowable deflection of the structure? The temp supports are a means/methods so your max vertical displacement numbers would be based on where you assumed the supports to be placed.

Response:

\*\*\*\*\*