

1050806 CONTRACTOR QUALITY CONTROL GENERAL REQUIREMENTS
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Alan Autry
414-4195

Comments: (12-6-11)

DCE memo 17-04 did not include provisions to waive the requirement for a CTPQ Level II technician to be present when placing temporary asphalt as is suggested by the origination file and comment included in the specification change. The waiver for a CTPQ level II technician when placing miscellaneous asphalt has already been addressed by a specification update prior to DCE memo 17-04 being "expired". Are we certain that we want to waive this requirement when temporary asphalt is being placed?

Response: This was a unanimous agreement by all the DBEs, SMO and Rich Hewitt of State Construction.
